


:hager

User instructions

To the customers for safety switches / circuit breaker combination



Test the safety switch periodically (approximately every three months) by pressing Test button marked "T".

Tripping

If tripping occurs, unplug all appliances. Reset switch. Individually plug in each appliance until the safety switch trips to determine the faulty appliance :

- 1- If the safety switch does not trip with individual appliances, then the circuit may be overloaded.
- 2- If the safety switch trips with no appliances connected, the installation cabling may be damaged. Consult an electrician.

INSTALLED BY :

Hager B&R Pty Ltd
Unit 1/170 Power Street Glendenning NSW 2761 AUSTRALIA
Tel: (61) 2-8867 7600 www.hagerbr.com.au

6A1400.a